

Safety/Energy Committee Minutes
Held In-Person/Zoom Hybrid; August 16, 2022

Present: Allen Risen, Nora Solvedt, Kevin Thibeault, Jessica Olson, Mike Hanson, Michelle Sides, Mark Lilley, Janelle Hampton, Rebecca Chiles, Mike Komes, Trenton Ellington, and Adria Henrickson.

Absent: Lindsey Lavender, Mike McGlade, Jacquelyn Vasquez, Julie Grammer, Kristen Larson, Beeb Singson, and Chelsea Blatner.

Meeting was called to order at 1400 hrs.

Review of Minutes:

- Michelle Sides made the motion to approve, Michael Hanson seconded.
- July 19th minutes approved.

Building Fire life Safety Inspections: Allen Risen.

Extinguisher Issues;

- Many extinguishers not receiving their monthly checks by assigned person for their building. I completed all annual inspection / servicing and replaced monthly inspection tags.
- Total of 59 fire extinguishers requiring their 6-year servicing. I depleted remaining inventory stock, replacing 29 extinguishers. 25 fire extinguishers still requiring their 6-year servicing. Natural Science (4) Health & Wellness (15) Old PE (4) Rice Auditorium (2) These extinguishers will still work. Waiting for inventory replacements to be returned (58) from their 6-year servicing off campus
- HSS broken extinguisher cabinet handle was replaced and able to open cabinet easily.

Trip/Fall Hazards;

- Maple Hall north sidewalk needs patched. Old patch chipped out causing a potential trip hazard.

Emergency Light Issues;

- Old PE x2
- Rice Auditorium x1
- Todd Hall x5
- WUC x1
- Campbell Hall x1

Fire Sprinklers;

- Health and Wellness Racquetball court #1 sprinkler head protective cover missing.
- Campbell Hall 308 has sprinkler head wrapped with black tape and needs removed.

Holes in walls/ceilings;

- WUC 5- holes in wall where old fire panel was once located.
- Rice Auditorium ceiling tiles missing above paint booth.
- Natural Science ceiling tiles missing in 3 locations.

Other;

- Health and Wellness; large hedge at west front entrance that was blocking pedestrian and vehicle traffic was cut back to give clear view to all. Thank you, Grounds department.

Injury Review: None this month.

Energy Conservation Update:

- Facilities Services is working with the Energy Trust of Oregon to update lighting in Stadium.
- Campus Public Safety and Parking Services are continuing to work on replacing vehicle charging stations.
- The work on the current section of the steam line should be finished later in August. Work on the second section will continue at a later date.

Round Table:

- Fire extinguisher training will take place in September.
- Sky Window Cleaners will be washing windows on campus.

Next Meeting: September 20, 2022, 2pm, in Hamersly Library 205.
Meeting adjourned at 1416 hrs.